

Approved body No. 1121

Certificate of constancy of performance

1121-CPR-UK-AAA7569

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

“BRITON 376 (See ANNEX A) 377 (See ANNEX B) 378 (See ANNEX C) 379 (See ANNEX D) Series” Panic Exit Devices

Intended use: For use on single and double leaf escape panic doors, including fire resisting doors.

Essential characteristics	Performance	Designated Standard
Mechanical Test Evidence : 145924 / 145925 / 172273 / 178803 / 178821 / 180622 / 181094 / 182650-A/B/D/E&J / 363384 / WIL 420093 & WIL 420136-2 / WIL 430256 / WIL 438044 & WIL 513902 Fire Test Evidence : 127579 / C128348 / 137635 / 140181 & 422916		
Clause 4.2.1 Ability to release (for doors on panic routes) Release function Panic exit device mounting Exposed edges and corners Double doorset Single doorset Bar installation Bar length Bar projection Bar end Operating bar face Test rod Door face gap Accessible gap Door free movement Top vertical bolt Covers for vertical rods Keepers Keepers dimensions Door mass and dimensions Outside access device Release forces Security requirement	< 1 sec Pass > 0,5 mm Pass Pass Z < 150 mm > 60% W < 100mm Pass > 18 mm Pass > 25 mm Pass Pass Pass – (376 Annex A & 377 Annex B Only) NPD Pass Pass – (376 Annex A & 377 Annex B Only) Door mass ≤ 200Kg, door height ≤ 2500mm, door width ≤ 1300mm Pass < 80N with the door unloaded, and < 220N with the door loaded with 1 000N Grade 2	BS EN 1125:2008
Clause 4.2.1 Durability of ability to release against aging and degradation (for doors on panic routes) Corrosion resistance Temperature range Covers for vertical rods Lubrication Re-engagement force Durability Abuse resistance –Horizontal bar Abuse resistance –Vertical rod Final examination	Grade 3 : 96 Hours Operating forces at -10 C° and + 60 C° < 50% in excess of the operating forces at +20 C° NPD Lubrication every 20 000 cycles < 50 N Grade 7: 200 000 cycles 1 000N 500N – (376 Annex A & 377 Annex B Only) < 80N with the door unloaded, and < 220N with the door loaded with 1 000N	

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7569

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Essential characteristics	Performance	Designated Standard
Clause 4.2.1 Self closing ability C (for fire/smoke doors on panic routes) Re-engagement force	< 50N	BS EN 1125:2008
Clause 4.2.1 Durability of self closing ability C against aging and degradation (for fire/smoke doors on panic routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on panic routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies – Additional requirements	Grade B : Suitable for use on fire door assemblies.	
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the devices do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7569

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

Briton Product	Single Door (Standard Keeper)	Double Door (Standard Keepers)	Approved with Alternate Strike or Keeper			
			378 DDS	376 MDS	378 MDS	379 MDS
ANNEX A						
376	✓	✓	-----	✓	-----	-----
376.A	✓	✓	-----	✓	-----	-----
376.P	✓	✓	-----	✓	-----	-----
376.D	✓	✓	-----	✓	-----	-----
376.PD	✓	✓	-----	✓	-----	-----
376M	✓	✓	-----	✓	-----	-----
376M.P	✓	✓	-----	✓	-----	-----
3760EM	✓	✓	-----	✓	-----	-----
3760EM.P	✓	✓	-----	✓	-----	-----
ANNEX B						
377	-----	✓	✓	✓	✓	-----
377M	-----	✓	✓	✓	✓	-----
ANNEX C						
378	✓	✓	✓	-----	✓	-----
378.D	✓	✓	✓	-----	✓	-----
378M	✓	✓	✓	-----	✓	-----
3780EM	✓	✓	✓	-----	✓	-----
ANNEX D						
379.N	✓	✓	-----	-----	-----	✓
379.NA	✓	✓	-----	-----	-----	✓
379.ND	✓	✓	-----	-----	-----	✓
379M.N	✓	✓	-----	-----	-----	✓
3790EM.N	✓	✓	-----	-----	-----	✓
Accessories						
Model Number	Description					
Briton 1413.LE	Lever outside access device (Suitable for use with all devices)					
Briton 1413.KE	Knob outside access device (Suitable for use with all devices)					
Briton 1413.BP	Retrofit Plate (Suitable for use with all devices)					
Briton 9260 Codelock	Lever outside access device (Suitable for use with 376 / 377 & 378 Only)					
Rim Cylinders	For use with 378 products only					

Approved body No. 1121

Certificate of Constancy of Performance

1121-CPR-UK-AAA7569

Placed on the market under the name of

**Allegion (UK) Ltd
35 Rocky Lane
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plant

V/017

This is coded format and the information is held by the Approved Body

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

BS EN 1125 : 2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **26/04/2023** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **25/04/2026**



0087



Paul Duggan
Certification Manager

**Warringtonfire Testing and Certification Limited
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**